

Hunter's Ridge road

This concrete pipe leads from SS-2-2 on Hunter's Ridge, the pipe is 24 inch RCP.

Section 1,
190" long
cracks

There is a small black plastic pipe that runs from a downspout and dumps water short of the concrete structure and contributes to the erosion of the concrete swale.

Section 2
132"
No cracks

Section 3
120"
Joint sep.

Section 4
122"
No Cracks

Section 5
136"
No Cracks

Section 6
151 long
48" wide no
cracks

Property line ends in about 1/3 of the way thru section 7. The other side is in Powhatan Plantation Resort.

Section 7
124"
No Cracks

This concrete swale continues for 225 feet and empties into a stream